

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6912-0067:237

Page 1 of 1

CATEGORY: Voice Communication Accessories

LISTEE: Siemens Building Technologies Inc., Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Audio Input Card (AIC), Zone Amplifier Card (ZAC-40), Zone Amplifier Module (ZAM-180), Digital Audio Card D-Net (DAC-NET), Live Page Board (LPB), Live Voice Module (LVM), Telephone Zone Card (TZC-8B), Fireman's Master Telephone (FMT), Firefighters Telephone Station (FTS, -C, -CL, -P, -PCL Series), Portable Fire Fighters Telephone (PFT, -P Series) Voice Communication Accessories. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as voice communication accessories for use with listee's separately listed Firefinder XLS (CSFM Listing No. 7170-0067:236) fire alarm control unit. Refer to listee's Installation Instruction Manual for details.

04-14-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**